

TYLin

PLANNING AHEAD

Implementing an Odor Control Strategy for Middlesex County Utilities Authority

Jessica Ping, Lisa Oberreiter, and Kimberly Smith
05/12/2026 | 3:30 pm





Agenda

1. MCUA Overview
2. Odor Sampling and Monitoring
3. Dispersion Modeling
4. Odor Control Strategies
5. New Odor Control System Evaluation
6. Current Updates


01 MCUA Overview

Middlesex County Utilities Authority

- Central Treatment Plant in Sayreville, NJ
- ~ 950,000 industrial, commercial, and residential users
- 147 MGD Design Capacity
- ~ 90 MGD Average Daily Flow
- Liquid Treatment Process
 - Grit Removal
 - Primary Sedimentation Tanks
 - Aeration Tanks w/ pure oxygen
 - Final Settling Tanks
 - Disinfection
- Solids Treatment Process
 - Gravity thickeners
 - Dewatering via BFPs
 - Drying
 - Lime Stabilization




Odor Complaints 2023-2026



02 Odor Sampling and Monitoring


Sampling Locations



Sampling Results

| No. | Location | Hydrogen Sulfide | Ammonia |
|-----|----------------------------|------------------|--------------|
| | | DT = 0.0047 ppm | DT = 5.0 ppm |
| 1 | Grit Tank Junction Chamber | 0.048 | 0.002 |
| 2 | Grit Tank Effluent | 0.574 | 0.0006 |
| 3 | Primary Sedimentation Tank | 2.872 | 0.009 |
| 4 | TTO Pump Station | 18.885 | 0.074 |
| 5 | Gravity Thickener | 0.169 | 0 |
| 6 | Belt Filter Press | 0.877 | 0.163 |
| 7 | Pasteurizer Conveyor | 0.001 | 6.601 |
| 8 | ChemFix Alternative | 0.001 | 0.059 |
| 9 | DuopHase Building | 0.003 | 0.195 |
| 10 | Curing Bunker | 0.002 | 2.027 |
| 11 | Process Exhaust Stack | 0.045 | 0.0006 |
| 12 | Odor Stack D1 | 0.102 | 0.005 |
| 13 | Odor Stack D2 | 0.001 | 0 |

Acrulog Monitoring Location



AcruLog Monitoring Results

| H2S AcruLog Monitoring | | |
|-------------------------------|----------------------|----------------------|
| | Average (ppm) | Maximum (ppm) |
| Grit Tank Effluent | 2.83 | 79.6 |
| TTO Pump Station | 0 | 0 |
| Gravity Thickener | 0 | 0 |
| Belt Filter Press | 0.95 | 48.1 |
| DuopHase Building | 0 | 0 |
| Curing Bunker | 0 | 0 |


| Ammonia AcruLog Monitoring | | |
|-----------------------------------|----------------------|----------------------|
| | Average (ppm) | Maximum (ppm) |
| TTO Pump Station | 0 | 0 |
| Belt Filter Press | 0 | 0 |
| DuopHase Building | 1.1 | 11 |
| Curing Bunker | 1.4 | 55 |

Identified Odor Sources for Dispersion Modeling




03 Dispersion Modeling

Dispersion Modeling - Baseline Conditions



Dispersion Modeling – Mitigation Condition



04 Odor Control Strategies

Best Management Practices

- Keep Gravity Thickener Tank covers closed.
- Adding sodium chlorite to gravity thickened sludge prior to dewatering.
- Keeping garage doors closed.
- As feasible, move biosolids material from DuopHase Building to Pasteurizers and Pasteurizers to Curing Bunker during evenings and nights.

TYLin




Best Management Practices

- Cleaning tanks that are emptied in a timely manner.
- Good housekeeping throughout plant to minimize scum and solids buildup in tanks.
- Adding Vanilla in the Mist, an enzymatic odor neutralizer and masking agent, onto truck beds and on top of loaded solids prior to tarping before trucks exit Curing Bunker.
- Continue routine switches of force mains approximately every 7 days to minimize odors that can occur if septic wastewater is introduced into grit chambers during force main changes.



Existing Odor Control Systems



Existing Odor Control Systems

| | OCS 1-4 Curing Bunker | OCS 5-6 DuopHase Building | OCS 7 Gravity Thickeners | Packed Tower OCS D1/D2 Dewatering Building |
|------------|--|---|---|---|
| Stage 1 | Sulfuric Acid 70-100% Removes ammonia and amines | Sulfuric Acid 93% | Sodium Hydroxide 15% Sodium Hypochlorite 25% | Sodium Hypochlorite 15% Sodium Hydroxide 25% Removes hydrogen sulfide |
| Stage 2 | Sodium Hypochlorite 10-15% Removes hydrogen sulfide | Sodium Hypochlorite 15% Sodium Hydroxide 25% | n/a | n/a |
| Stage 3 | Sodium Hydroxide 50% | n/a | n/a | n/a |
| Operations | At least 2 trains operating | At least 1 train operating | Can be turned off December 15-March 15 | Both operating at all times, except for maintenance |


05 New Odor Control System Evaluation



Odor Control Alternatives

- Grit Chambers
- Primary Sedimentation Tanks (PSTs)
- Combined PSTs and Grit Chambers
- TTO Pump Station
- Odor Control Technologies Evaluated:
 - Chemical Scrubbers
 - Granular Activated Carbon (GAC)
 - Biotrickling Filter with Mixed Media
 - Hybrid (Biological and Carbon) System

Grit Chamber Odor Control System



PST Odor Control System

Influent Channel (aerated)



Effluent Channel



Protective Coating

Combined PSTs and Grit Chambers

New Odor Control System Evaluation

| Combined PSTs and Grit Chambers | | | | | | | | | |
|-----------------------------------|------------|-------------|----------------|---------------------------------------|----------------|---------------|----------------|-------------------|----------------|
| Evaluation Criteria | Weighting | GAC | | Biological Filter w/ Engineered Media | | Hybrid System | | Chemical Scrubber | |
| | | Score (1-4) | Weighted Score | Score (1-4) | Weighted Score | Score (1-4) | Weighted Score | Score (1-4) | Weighted Score |
| Total 20-Year Present Worth Costs | 40 | 4 | 160 | 3 | 120 | 2 | 80 | 1 | 40 |
| Odor Control System Reliability | 60 | 2 | 120 | 3 | 180 | 4 | 240 | 1 | 60 |
| Total | 100 | -- | 280 | -- | 300 | -- | 320 | -- | 100 |

Scores: 1 = least favorable, 4 = most favorable


Odor Control System Recommendations




06 Current Updates

Aerated Grit Chamber Project

- Contract Awarded June 2025
- Project Includes:
 - Installation of chamber covers and new odor control unit
 - Replacement of grit removal system with continuous grit removal with grit washers
- Air from under the covers will be treated via a new V2 Carbon Adsorber Odor Control System, which will limit odors.
- The system is designed for an air flow rate of 11,000 cfm for continuous service.



Aerated Grit Chamber Project



Envirosuite

- Installed in March 2026
- Two monitors along Main Street Extension measure:
 - Volatile Organic Compounds
 - Hydrogen Sulfide
 - Ammonia
- On-site weather station
- Allows for real-time validation of odor complaints
- Modelling application shows potential odor impacts to the community based on weather data

Modelling

MODEL SETUP

Model Intervals

10 min

60 min

Date/Time

May 1, 2026, 6:00 AM



Auto Update



Model From

-0 min

Model To

+24 hr

MODELS

Forecast H2S (ppb)



Forecast Wind




EMISSION SOURCES

Display Emission Sources




Envirosuite Monitors


Volatile Organic Compounds



Hydrogen Sulfide



Ammonia





Biosolids Master Plan

- Odor Study of Biosolids Process Areas
 - Odor Control Sampling Plan developed
 - Sampling scheduled for end of month
- Odor survey to focus on:
 - Hydrogen Sulfide
 - Ammonia
 - Reduced Sulfer Compounds (RSCs)
 - Amines
 - VOCs
 - Odor (D/T)
- Better understand performance of individual OCS's
- Acrulog data to define durational patterns

Thank you and Questions?

CONTACT US

JESSICA PING, PHD, PE

Civil Engineer / Project Engineer, TYLin

Jessica.Ping@tylin.com

+1 212.693.9527

LISA OBERREITER, S4,C3,MPA

General Superintendent, MCUA

LOberreiter@mcua.com

+1 732.721.3800 Ext.230

KIMBERLY SMITH, CHMM

Senior Environmental Quality Scientist, MCUA

ksmith@mcua.com

+1 732.721.3800 Ext. 293